



Fire & Life Safety Evaluation

Incomplete

SHSU Campus Name:

Building Name:

Building Number:

Conducted By:

Occupancy Type:

Date of Inspection

Inspection

Fire Protection, NFPA 72 & NFPA 25

Does the building have a fire alarm system?

Does the building have a fire sprinkler system?

Yes

Is the required inspection up to date?

Is the fire sprinkler system control valve secured in the open position

Yes

Is the fire department connection free of obstructions, undamaged and has signage?

Is the standpipe system and hose connections free of obstructions and undamaged?

Are the fire extinguishers clear of obstructions, undamaged and operational?

Are fire suppression systems (kitchen hood systems & FM200 systems) inspected and operational?

NOTES

Means of Egress, NFPA 101

Are Emergency Evacuations plans posted and accurate?

Are the pathways to, through and beyond the means of egress clear of obstructions?

Do the doors in the means of egress open, close and latch properly?

Do the fire doors open, close and latch properly?

Is the means of egress illuminated when the building is occupied?

Is the emergency lighting operational?

Are the Exit lights operational?

Does the Exit signage direct you to the closest exit?

Are stairwells clear of obstruction and storage?

NOTES

Electrical, NFPA 70

Are the outlets within 6' of wet areas protected by a GFCI?

Do junction, switch and outlet boxes have covers?

Is there clear access to electrical panels?

Are the electrical panels in public areas locked?

Are the breakers in the electrical panels adequate labeled?

Is the cover plate inside the electrical panel free of holes?

Are power strips and extension cords used safely?

NOTES

Mechanical/Electrical Rooms, NFPA 101

Are the mechanical rooms clear of combustible materials and stored items?

Are penetrations through walls, floors and ceilings sealed with fire proofing materials?

NOTES

Storage NFPA 1 Fire Code

Are flammable & combustible liquids stored in a flammable storage cabinet?

Is there 18" of clearance provided below sprinkler heads?

Is there 24" of clearance below to ceiling in non-sprinkled areas?

Are items stored properly? I.E. Off the floor, neatly, and not excessive?

MISCELLANEOUS

ADDITIONAL COMMENTS